



X = VARIABLE ACCORDING TO WINDZONE REFER TO E2/AS1, Table 7.

NOTE : - IF ROOF IS BEING USED AS AN INTERNAL GUTTER, THE CLADDING MUST BE MIN. 100mm ABOVE MEMBRANE SURFACE

22 PARAPET METAL CAPPING