



X = VARIABLE ACCORDING TO WINDZONE
REFER TO E2/AS1, Table 7.

NOTE : - IF ROOF IS BEING USED
AS AN INTERNAL GUTTER, THE
CLADDING MUST BE MIN. 100mm
ABOVE MEMBRANE SURFACE

28A PARAPET METAL CAPPING