

**NOTE : IF HANDRAIL TOP IS WIDER THAN 300mm - IT MUST HAVE A MINIMUM SLOPE OF 30°**

TWO LAYERS OF REINFORCING FIBREGLASS MESH OVER SURFACE OF EIFS TAPE MEMBRANE EXTEND DOWN EACH SIDE MIN. DISTANCE OF 50mm

15° MIN. SLOPE

3mm THICK EPDM GASKET BETWEEN PLASTER & BRACKET

PUNCHED BASE BEAD

TIMBER BLOCK MUST BE COVERED WITH A WATERPROOF MEMBRANE PATCH COVERING POLYSTYRENE BY A MIN. OF 50mm

H3.1 FIXING BLOCKS MUST BE PLACED AT THE FRONT OF WALL NOT THE TOP

CAVITY BATTENS

BREATHER TYPE WRAP CONTINUOUS OVER FACE OF STRUCTURE BY BUILDER

35mm MIN

20mm CAVITY

WATERPROOFING MEMBRANE MUST EXTEND A MINIMUM OF 150mm UP ANY VERTICAL SURFACE

# 30 BALCONY CAPPING